



Illinois Environmental Protection Agency · P.O. Box 19276, Springfield, IL 62794-9276

217/782-9720

National Steel Corporation
Granite City Steel WWTP
NPDES Permit No. IL0000329
Report of Compliance Sampling Inspection

EPA Region 5 Records Ctr.



320315

March 8, 1991

Mr. Fred Steinkuehler
Director Facility Services
National Steel Corporation
Granite City Steel
20th and State Streets
Granite City, Illinois 62040

Dear Mr. Steinkuehler:

On December 5, 1990, an NPDES Compliance Inspection was conducted at the subject facility by personnel from the Collinsville Regional Office. From the report supplied by the field inspector, the only recommendation which will be made at this time is as follows:

All seepage at the blast furnace pond (dewatering areas #1 and #2) should be diverted into the collection ditch.

This Agency would like to commend the operating staff for their efforts. Should any questions arise pertaining to this letter, they may be directed to me at the above-indicated telephone number.

Sincerely,

Barbara Conner
Compliance Monitoring Unit
Compliance Assurance Section
Division of Water Pollution Control

BC:bw

cc: CAS
Records Unit ✓
Region 6